PC33 & 52

Analog Relative Humidity and Temperature Probe

The PC33 & 52 series offers a comprehensive range of relative humidity probes for accurate, stable and repeatable measurements. Available with analog output signals, the PC series can be installed in a wide variety of applications.




Highlights

- Low cost PC33 with analog output is designed for HVAC applications
- PC52 with analog output is designed for accurate measurement in controlled environments
- Analog zero and span adjustment

Technical Specifications

Performance				
Measurement range (RH)	0-100% RH			
Measurement range (T)	-20 to +80°C (-4 to +176°F)			
Accuracy @ 23°C (73°F) humidity	PC52: <±2% RH (10-90% RH) PC33: <±3% RH (30-80% RH)			
Accuracy @ 23°C (73°F) temperature	PC52: ±0.2°C (±0.36°F) PC33: ±0.3°C (±0.54°F)			
Stability - RH Sensor	±1% RH / year			
Response time – RH Sensor	<10 sec typical (for 90% of the step change)			
Electrical Specification	ons			
Output signal options	4–20 mA, 0 to 1, 0 to 5, 0 to 10 V			
Supply voltage	14 to 30 V DC (for 0 to 5 / 0 to 10 V output) 5 to 30 V DC (0 to 1 V & mA output)			
Operating Specifications				
Operating temperature Probe, Housing Storage	-30 to +85°C (-22 to +185°F) -40 to +85°C (-40 to +185°F)			
Mechanical Specifica	tions			
Ingress protection	IP65 (NEMA 4 level)			
Housing material	Molded polymer or stainless steel (ordering option)			
Dimensions	L=130mm, ø19mm (L=5.11", ø0.74")			
Weight	30g (1.06oz) without cable (molded polymer version)			
Electrical connections	M12			

Dimensions



Electrical Connections

	Voltage Output	
Mating Cable		Pin
White	Power Supply V +	1
Yellow	Output temperature +	2
Brown	Common ground	3
Green	Output RH +	4

4-20 mA Output 2-wire			
Mating Cable		Pin	
White	Output RH +	1	
Yellow	Output temperature -	2	
Brown	Output RH -	3	
Green	Output temperature +	4	

Michell Instruments 48 Lancaster Way Business Park, Ely, Cambridgeshire, CB6 3NW

Tel: +44 (0) 1353 658000, Fax: +44 (0) 1353 658199, Email: info@michell.com, Web: www.michell.com/uk

Michell Instruments adopts a continuous development programme which sometimes necessitates specification changes without notice. Issue no: PC33&52_97178_V4_UK_0616

